



GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT

From,
The Station Fire Officer,
Fire Station Malakpet,
Hyderabad, T.S.

To,
M/S BRAHM PRAKASH DEV SCHOOL,
Midhani Township
Kanchanbagh, Hyderabad,
Telangana State.

**Sub: Telangana State Disaster Response and Fire Services Department–Central Region
Hyderabad Division–Fire Station Malakpet– Fire Protection and Control – Inspection
Of M/S BRAHM PRAKASH DEV SCHOOL Midhani Township Kanchanbagh,
Hyderabad , Telangana. Premises against Fire Precautionary and Fire Preventive Measures
Regarding.**

- Ref:** 1. Annexure – XVII Fire Services Manual Rule.
2. D.O. Lr No. 4646/A1/2002 dated 20-08-2002 of Principal Secretary to Government,
Home Department A.P. Secretariat Hyderabad.
3. D.O. Lr No.856/B2/99 dated 04-09-2002 of D.G. Fire Services Hyderabad.
4. Application date 09/04/2024.

On inspection of the above mentioned premises on 11/04/2024 it was found that the Fire Precautionary and Fire Preventive Measures has been provided in the above premises.

1. **TEN** No's of ABC Type Fire Extinguishers of 6 Kg capacity provided.
2. **ONE** No's of CO2 Type Fire Extinguishers of 4.5 Kg capacity provided at electrical mains.
3. **TWO** No's of DCP Type Fire Extinguishers of 4.5 Kg capacity provided at electrical mains
4. **FOUR** No's of Fire Buckets round bottomed each of 9 Liters capacity provided.
5. **1000** Liters Terrace Water tank
6. **ONE** No's of CO2 Type Fire Extinguishers of 4.5 Kg capacity provided

All the Fire Fighting Extinguishers should be available within a radius of 15 meters with all staff and occupant must know the correct method of operation of the Fire Fighting System.


In addition of above management is requested to provide the fire fighting installation.

SUGGESTION:-

1. One standard first-Aid box with complete medical equipment shall be provided.
2. Naked flame should not be used inside the premises.
3. Electric wiring should be checked periodically and ensure no loose wiring.

The management should maintain the above Fire Fighting Equipments in good working condition to tackle the Fire in case of emergency.

Next Renewal Date: **APRIL-2025.**


**STATION FIRE OFFICER
FIRE STATION MALAKPET,
HYDERABAD.**