


SAFE DRINKING WATER AND SANITARY CERTIFICATE

Date : 20-04-2026 .


This is to certify that an inspection team headed by Dr. D Rajender, Medical & Health Officer, UPHC Uppuguda, Hyderabad inspected the Brahm Prakash DAV School, Located at Survey No 87/1, Midhani Township, Kanchanbagh, Rangareddy District, Hyderabad on 18-04-2026 and found that M/s Brahm Prakash DAV School Located at Survey. No 87/1, Midhani Township, Kanchanbagh, Rangareddy District, Hyderabad has safe drinking water facilities for its students and staff members. They are maintaining the hygienic sanitation conditions in the school building & the campus as per the norms. This certificate is valid for the academic year 2026-27.

To,
Brahm Prakash DAV School, Located at Sy. No. 87/1,
Midhani Township, Kanchanbagh, Rangareddy District,
Hyderabad.

Signature


23/4/2026

Dr. D. RAJENDER
Reg. No: 71465
CIVIL ASST. SURGEON
AREA HOSPITAL
Vanasthalipuram, R.R. Dist.


PRINCIPAL
BRAHM PRAKASH D.A.V. SCHOOL
Affiliated to CBSE NEW DELHI No. 3630017
Midhani Township, Kanchanbagh,
HYDERABAD-500 058, TELANGANA STATE



Vista Labs

Analytical • Biological • Environmental

An ISO 9001:2015 &
OHSAS ISO 45001:2018 Certified Lab



Regn. No.23DQLD43

TEST REPORT

Page 1 of 1

Name & Address Of Customer: M/s. B.P.D.A.V Public School Midhani Township, Hyderabad. C/o. Trinity Appliances & Services.	Lab Ref. No:	VIS/6831/2026	
	Reporting Date:	11/03/2026	
	Sample Received On:	10/03/2026	
	Your Ref No:	Verbal	
	Sample Description: R.O.water	Analysis Started On:	10/03/2026
Sample Condition At the time of Receipt: Found OK	Date of Sampling:	10/03/2026	
Sample drawn By: Customer	Quantity Received: 1Ltr X 1No.	Analysis Completed On:	11/03/2026

TEST RESULTS

Sl. No.	Characteristic Physical & Chemical	Test method	Results	Requirement (Acceptable Limit) As per IS 10500:2012
1.	P ^H Value at 25°C	IS:3025(Part -11)-1983,RA 2017	6.94	6.50 - 8.50
2.	Electrical conductivity @ 25°C, µS/cm	APHA (23 rd Edn:2017) -2510 B	90	Not specified
3.	Total Dissolved solids, mg/l	IS:3025(Part -16)-1984,RA 2006	58	< 500
4.	Turbidity, (NTU)	IS:3025(Part -10)-1984,RA 2017	< 1.0	< 1.0
5.	Colour, (Hazen Units)	IS:3025(Part - 4)-1983,RA 2017	< 02	< 05
6.	Odour	IS:3025(Part - 5)-1983,RA 2018	Agreeable	Agreeable
7.	Total Hardness as CaCO ₃ , mg/l	IS:3025(Part -21)-2009,RA 2014	13	< 200
8.	Alkalinity to Phenolphthalein as CaCO ₃ , mg/l	IS:3025(Part -23)-1986,RA 2014	Nil	Not specified
9.	Alkalinity to methyl orange as CaCO ₃ , mg/l	IS:3025(Part -23)-1986,RA 2014	30	< 200
10.	Calcium as Ca, mg/l	IS:3025(Part -40)1991,RA 2014	3.2	< 75
11.	Magnesium as Mg, mg/l	APHA (23 rd Edn:2017)-3500-Mg B	< 2.0	< 30
12.	Sodium as Na, mg/l	IS:3025(Part -45)-1993,RA 2014	14.7	Not specified
13.	Potassium as K, mg/l	IS:3025(Part -45)-1993,RA 2014	< 1.0	Not specified
14.	Chloride as Cl, mg/l	IS:3025(Part -32)-1988,RA 2014	10.6	< 250
15.	Sulphate as SO ₄ , mg/l	IS:3025(Part -24)-1986,RA 2014	< 5.0	< 200
16.	Nitrate as NO ₃ , mg/l	IS:3025(Part -34)-1988,RA 2014	< 0.1	< 45
17.	Fluoride as F, mg/l	APHA (23 rd Edn:2017)-4500-F D	0.50	< 1.0
18.	Total Silica as SiO ₂ , mg/l	APHA (23 rd Edn:2017)- 4500 SiO ₂ C	< 1.0	Not specified
19.	Iron as Fe, mg/l	APHA (23 rd Edn:2017)- 3500 Fe B	0.050	< 0.3

Note: IS 10500: 2012 = Drinking water Specification

1. This report is valid for the tested sample(s) only.
2. Test report shall not be reproduced except in full & with written approval of VISTALABS.
3. This report should not be used for advertisement / judicial purpose.
4. Total Number Of Test(S) NINETEEN Only.
5. Lab will maintain unused portions of samples for 15 days after the report has been issued.

***** End of Report*****

Checked By

PRINCIPAL
 BRAHM PRAKASH D.A.V. SCHOOL
 Affiliated to CBSE NEW DELHI No. 3630017
 Midhani Township, Kancharanbagh,
 HYDERABAD-500 058, TELANGANA STATE

Authorized Signatory

VIS/LAB/F/047

4-9-6, Flat No. 103 & 104, Surya Towers, Adj. ANK Gardens, HMT Nagar, Nacharam, Hyderabad-500 076.
 Ph : 040-27173815, 42210081, E-mail : vistalabs@yahoo.co.in, vistalabs2004@gmail.com